CIVIL-TECH CONSULTANTS AND ENGINEERS

Building & Highway Material Testing Laboratory

An ISO 9001:2008 Certified Company

NABL - Accredited Laboratory as per ISO / IEC-17025 : 2005

JAS-ANZ BSCIC ISO 9001 REGISTERED

Job No.: CTCE/BBMP/W.No.07/YSK /STEEL/2014-15 20.07.2014

TEST REPORT ON REINFORCEMENT STEEL

Client	:	**Asst. Executive Engineer**, Kodigehalli Sub Division, BBMP, Bangalore.
Agency	:	**Mr. Y. S. Krishnashetty,** Contractor, Bangalore.
Name of the Work	:	Construction of concrete road in Sanjeevanagara in Ward No.07 (Byatarayanapura) in Kodigehalli sub Division, BBMP, Bangalore.
Reference	:	AEE/(KOD.SUB.DIV)/353/2014-15 Dated: 09.07.2014
Date of Test	:	20.07.2014
Technical Reference	:	IS: 1786-2008

Sl. No	Nominal size (dia) (mm)	Mass per metre (Kg/mtr)	TENSILE STRENGTH			Bend Test	Rebend Test
			0.20% proof stress/Yield stress N/mm^2	Tensile strength (Ultimate stress) N/mm^2	Elongation percent gauge length		
1	12	0.89	515	558	13.30	O.K	O.K

Note:

⇒ The report shall not be reproduced, except in full, without the written approval of the laboratory.

⇒ The results indicated above are based on the tests carried out on the samples received in the laboratory.

⇒ Any Query regarding the report must be reported within 30 days from the date of testing.

M/s. Civil-Tech Consultants & Engineers
23/14, 7th Cross, 3rd Stage,
4th Block, Shakthiganapathinagara,
Basaveshwaranagar,
Bangalore-560079.

CIVIL-TECH CONSULTANTS AND ENGINEERS

Building & Highway Material Testing Laboratory

An ISO 9001:2008 Certified Company

NABL - Accredited Laboratory as per ISO / IEC-17025 : 2005

JAS-ANZ BSCIC ISO 9001 REGISTERED

Job No.: CTCE/BBMP/W.No.07/YSK /STEEL/2014-15 20.07.2014

TEST REPORT ON REINFORCEMENT STEEL

Client	:	**Asst. Executive Engineer**, Kodigehalli Sub Division, BBMP, Bangalore.
Agency	:	**Mr. Y. S. Krishnashetty,** Contractor, Bangalore.
Name of the Work	:	Construction of concrete road in Sanjeevanagara in Ward No.07 (Byatarayanapura) in Kodigehalli sub Division, BBMP, Bangalore.
Reference	:	AEE/(KOD.SUB.DIV)/353/2014-15 Dated: 09.07.2014
Date of Test	:	20.07.2014
Technical Reference	:	IS: 1786-2008

Sl. No	Nominal size (dia) (mm)	Mass per metre (Kg/mtr)	TENSILE STRENGTH			Bend Test	Rebend Test
			0.20% proof stress/Yield stress N/mm^2	Tensile strength (Ultimate stress) N/mm^2	Elongation percent gauge length		
1	16	1.58	520	563	13.55	O.K	O.K

Note:

⇒ The report shall not be reproduced, except in full, without the written approval of the laboratory.

⇒ The results indicated above are based on the tests carried out on the samples received in the laboratory.

⇒ Any Query regarding the report must be reported within 30 days from the date of testing.

M/s. Civil-Tech Consultants & Engineers
23/14, 7th Cross, 3rd Stage,
4th Block, Shakthiganapathinagara,
Basaveshwaranagar,
Bangalore-560079.